

CNL Event Reporting 2017/2018 3rd Quarter (October, November, December)

Event Number	Title
OPS-17-4531	Standard warning barrier not re-established after maintenance works
D&WM-17-4649	Anomalous readings from Optically Stimulated Luminescent Dosimeters
D&WM-17-4803	Temporary loss of remote communication with the site of Nuclear Power Demonstration reactor
D&WM-17-4932	Temporary lighting issue in the canister storage area at Douglas Point
ENG-17-4948	Fire Sprinkler Freeze in women's washroom
P&NO-17-4982	Breach of Security Protocol
OPS-17-5278	Spurious flow signal at NRU
OPS-17-5390	Air effluent Action Level exceedance of Iodine-131
D&WM-17-5462	Potential administrative non-compliance at Whiteshell Waste Management Area