

CNL Event Reporting 2018/2019 2nd Quarter (July, August, September)

Event Number	Title
P&NO-18-2241	Unidentified gamma dose rate greater than 2.5mrem/hr discovered in a Radiation and Contamination zone
P&NO-18-2596	>2.5 mrem/hr in accessible location not signed or guarded
D&WM-18-2742	HWP - PH WWTP - Arsenic Action Level Exceedance
D&WM-18-2780	HWP - PH WWTP - Arsenic Action level exceedance
D&WM-18-2951	NPD – Temporary loss of remote alarm monitoring between NPD and CRL
OPS-18-2960	Air Effluent Exceedance of Gross Beta, Action Level at B109 Stack during the monitoring week starting 2018-Jul-18
OPS-18-2963	B570 Area Health Monitor RMS III Calibration checks found deficient
D&WM-18-3073	Unintentional raising of fuel can during fuel shroud retrieval
P&NO-18-3075	Damaged IAEA Seals Discovered
D&WM-18-3224	Temporary loss of Power to IAEA Portal Monitor at PH LTWMF
P&NO-18-3309	Corroded culvert discovered - culvert used to move B610 weeping tile water to 040 Outfall
D&WM-18-3496	NPD - Diesel Generator Class III shutdown results in no power to facility for an hour
P&NO-18-3401	NRF Officer Lapsed Fitness Qualification