

**CNL Event Reporting 2021/22 2<sup>nd</sup> Quarter (July, August, September)**

Event Number	Title
HSSE-21-2045	Security Reportable Event
ERM-21-2078	Liquid Found Leaking from Waste Package in WMA-H RSSA
ERM-21-2165	DPWF Fire Protection Program Non-Conformances
HSSE-21-2169	Continuous Air Monitor (CAM) found past its Calibration date
HSSE-21-2175	Temporary Breach of Fire Minimum Complement
ERM-21-2269	HWP - PH SSS - Overhead Powerline Strike
HSSE-21-2331	Annual Fire Alarm Testing Overdue PMM's
ERM-21-2362	HWP - PG WWTP - Copper Action Concentration Exceedance
CTA-21-2541	Activation of Crisis Management Team due to IT Outage
HSSE-21-2650	Security Reportable Event
S&T-21-2655	Air Effluent Exceedance of Gross Beta Action Level at B375 Fan E16/25