

CNL Event Reporting 2021/22 4th Quarter (January, February, March)

Event Number	Title
HSSE-22-0089	Unplanned Underground Firewater Impairment - South Loop
HSSE-22-0108	Unplanned Sprinkler Impairment in B179
ERM-22-0165	Loss of Power to NRU EAFS Fans
S&T-22-0209	Area radiation monitor found out of calibration
HSSE-22-0145	HWP - PG LTWMF - Process residual waste totes were shipped without proper classification
HSSE-22-0317	Firewater break near B466 and activation of EOC
ERM-22-0386	B243 Tank 4 Unplanned Level Increase (related to firewater line break HSSE-22-0317)
ERM-22-0575	Leak from pipe at Spring B B598 small leak 10-40 liters ,contained immediately
ERM-22-0645	Vehicle driven over snow covered Tile Holes at WMA B
HSSE-22-0772	Firewater break in front of B375
ERM-22-0866	Marking covered up on incoming TDG package